OSHAWA PUC NETWORKS INC. DISTRIBUTION STANDARDS RESIDENTIAL OVERHEAD ELECTRICAL SERVICE & METER SOCKET						12-003	
SINGLE PHASE, 3 WIRE 120/240V							
POINT OF ATTACHMENT							
CSA APPROVED MAST 2 1/2" AS PER							
ONTARIO ELECTRICAL SAFETY CODE							
	3S						
4.5 m MINIMUM							
NO FENCES, SHRUBS, TREES OR OTHER OBSTRUCTIONS THAT WILL LIMIT ACCESS							
TO METER SHALL BE PERMITTED							
1.75 m							
							IEUTRAL
				FINAL GRAD		В	LOCK
	APPROVED	MICROLECTRIC * BS2-TV	HYDEL *SLC400RW	CUTLER-HAMMER *LU2			
	METER SOCKETS	002 11	/E400RO				
NOTES:		MPLETE WITH	MECHANICA	LLUGS			
1. TOLERANCE ON DIMENSIONS +/- 10%.							
2. THE METER SOCKET MUST BE MOUNTED ON AN OUTSIDE WALL AT A LOCATION							
APPROVED BY OPUCN METER DEPARTMENT TO CO-ORDINATE WITH DISTRIBUTION ON THE STREET.							
3. ELECTRICAL SERVICE SHALL MEET ALL ESA INSPECTION STANDARDS							
AND SHALL BE INSPECTED BY ESA BEFORE CONNECTION TO THE DISTRIBUTION SYSTEM.							
4. REFER TO "OPUCN APPROVED METER SOCKET TYPES" FOR SOCKET REQUIREMENTS.							
5. NO LB, LL OR LR FITTINGS ON THE LINE SIDE (AHEAD OF) THE METER							
BASE. 6. MINIMUM 1M CLEARANCE IS REQUIRED BETWEEN THE GAS METER/RELIEF VENT						METRIC	IMPERIAL (APPROX.)
AND THE ELECTRIC METER SOCKET.						1m 1.75m	3'-3"
						1.75m 3m	5'-8" 10'-0"
						4.5m	15'-0"
Oshawa	DRAWN:	KAB	CKD:		APP:		
PUC Networks In	nc. DATE:	MAY 10, 2017	1	SCALE:	NTS		REV: 1